DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 8-16-10
PROPOSED FACILITY: SFR PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: .67AC
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: • Private • Public • Well • Spring • Other _____
EVALUATION METHOD: • Auger Boring • Pit • Cut TYPE OF WASTEWATER: • Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L2% LINEAR	0-29	SCL MSBK	SSS PSCP	UFK	48"	—	—	.35
		29-44	SCM SBK	SSS PSCP	FR				
		44-48	CL WSBK	SSS SCP	UFR FEW SAP				
2	L2% LINEAR	0-21	CM SBK	SSS PSCP	FR	48"	—	—	.3
		21-48	SCL MSBK	SSS PSCP	UFR				
3	11 11	0-46	CM SBK	SSS SCP	FEW SAP	48"	—	—	.3
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	25	25
System Type(s)		
Site LTAR	.3	.3

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____