IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Butner Builders DATE 10/29/79 PERMIT NO. 377

PHONE: Business _____ Home _____

LOCATION 1155 TR 1102

_____ S. R. No. _____


SUBDIVISION NAME Sailor's Lair LOT NO. 14 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 3/4 acre

Character & Porosity of Soil Clay loam
Percolation Rate 80 min/in
Topography 10-15% Slope
Depth to Water Table ~~Unk~~ 10
Rock or other impervious formations None observed



Plot of System

1000 - back
1520 - front
Size of Tank ~~1250~~ Gals.
Nitrification Field:
No. of Lines 2-back 4 front
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Cranmer

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Cranmer DATE 10/29/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold