4634 692770

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR D. L. McNeely Const. DATE Dec. 11, '79 PERMIT NO. 426

PHONE: Business _____ Home _____

LOCATION 1102 TRon 1268

_____ S. R. No. _____

SUBDIVISION NAME Sailors Lair LOT NO. 13 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area ~1/2 AC.

Character & Porosity of Soil clay loam
Percolation Rate 80 mpi
Topography 8%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

800 gal tank + 100 linear ft. for basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Bill Bowman

IMPROVEMENTS PERMIT BY HRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Henson DATE 12-11-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold