IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR D. S. McNeely Const. DATE Dec. 14, '79 PERMIT NO. 426

PHONE: Business _____ Home _____

LOCATION 1102 Iron 1268

S. R. No. _____

SUBDIVISION NAME Sailors Lair LOT NO. 13 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes (✓)	No ( )	Character & Porosity of Soil	sandy clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	8%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
			Rock or other impervious formations	none obs.	

Lot Area ~1/2 ac.

800 gal tank + 100 linear ft. for basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Bill Bowman

IMPROVEMENTS PERMIT BY IRH

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 12-14-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold