IREDELL COUNTY HEALTH DEPARTMENT 4634693777

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Butner Builders DATE 5-14-79 PERMIT NO. 138

PHONE: Business _____ Home _____

LOCATION 1153 TR on 1102 near and on Rt _____


_____ S. R. No. _____

SUBDIVISION NAME Sailors Lair LOT NO. 12 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	—	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+	
Lot Area 3/4 AC			Rock or other impervious formations	none	



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by F J Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Mark K. Hanson DATE 5-14-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold