4631695918

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Southern Constructors DATE 9/18/79 PERMIT NO. 323

PHONE: Business _____ Home _____

LOCATION 1155 TR 1102 TR onto Sailor's Lane

_____ S. R. No. _____

SUBDIVISION NAME Sailor's Lane LOT NO. 10 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area Large

Character & Porosity of Soil Clay Loam
Percolation Rate 80 MPI
Topography 2-4% Slope
Depth to Water Table _____
Rock or other impervious formations NONE OBSERVED



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: Note: Bed has only 10" STONE

CERTIFICATE OF COMPLETION BY Fred Clemmer DATE 9/18/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold