4634792289

# IREDELL COUNTY HEALTH DEPARTMENT

## (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. E. Hastings DATE 3-12-96 PERMIT NO. 53

PHONE: Business _____ Home 872-3141

LOCATION 115 S R on 1162 Lot Resid. Troutman

S. R. No. _____

SUBDIVISION NAME Lake Norman LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

| | | | |
|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | |
| Auto. Dishwasher | Yes (✓) | No ( ) | |
| Auto. Wash Machine | Yes (✓) | No ( ) | |
| Site Suitable | Yes (✓) | No ( ) | |

Lot Area 1.4 Acres


Character & Porosity of Soil Clay loam Fair

Percolation Rate 30 Min/Inch

Topography 2 to 5% Slope

Depth to Water Table 6 to 8' +

Rock or other impervious formations None




Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 675 Linear Ft. 220

Depth of Stone in Lines 10

Water Supply: Individual (✓)

Public ( )

Installed by F. Sisson

IMPROVEMENTS PERMIT BY John Houston

COMMENTS _____

CERTIFICATE OF COMPLETION BY John Houston DATE 5-1-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold