4634796788

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Stuart Homes DATE 1-11-79 PERMIT NO. 15

PHONE: Business 596-0713 Home

LOCATION Blk 5 TR on 1102

S. R. No.

SUBDIVISION NAME Lake View Shores LOT NO. 2C SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ½ ac


Character & Porosity of Soil Clay loam

Percolation Rate 60 min/in

Topography 2 to 5%

Depth to Water Table 10'

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Blake Hyde

IMPROVEMENTS PERMIT BY

COMMENTS:

CERTIFICATE OF COMPLETION BY John Hoerstow DATE 1-11-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold