DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Lakeview Homes Inc OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 8/25/94
PROPOSED FACILITY: 3 bedroom SF dwelling
PROPERTY SIZE:
LOCATION OF SITE: Lot 18, Royal Pt.
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Borings ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1955 SAPRLT CLASS	HORIZON LTAR
1	LS 2-4% SI. bwd	0-5	SAB / CL	1:1 / fr					.3
		5-19	SAB / C	1:1 / fi-vfi					
		19-39	wk SAB / SC	1:1 / vfi-efi					
		39-48+	WK SAB / SIC	1:1 / vfi					
2									
3									
4									
5									

AVAILABLE SPACE (.1948): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE .65
EVALUATED BY: DMJohnson OTHER(S) PRESENT:
COMMENTS: Site can be reclassified PS per rule .1956 modified systems
PPBPS.