DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Jim Wilson OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___
PROPERTY SIZE: ___
LOCATION OF SITE: Lot 14
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-5	SBK / SiL	1:1 / S SP FR					(3)
		6-21	SBK / cl	1:1 / SS SP FR					
		22-29	SBK / cl	1:1 / SS SP FR					
		30-47	SG / mcl	1:1 / SS SP FR					
2		0-7	wk sbk / HCl	1:1 / SS SP FI					
		8-18	wk sbk / cl	1:1 / S P FI					
		19-36	Sbk / Sa cl	1:1 / SS SP FR					(1.3)
		37-47	FI sbk / Si cl	1:1 / SS NP FR					
3									
4									
5									

AVAILABLE SPACE (.1945) ___ SITE CLASSIFICATION (.1948): ___ SITE LONG-TERM ACCEPTANCE RATE: ___

EVALUATED BY: ___ OTHER(S) PRESENT: ___

COMMENTS: ___