DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet of

PROPERTY ID #:

COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Diane Parker

APPLICATION DATE

ADDRESS:

DATE EVALUATED:

PROPOSED FACILITY: 4 bedroom PROPOSED DESIGN FLOW (.1949): 480gpd

PROPERTY SIZE:

LOCATION OF SITE: Kings Landing 59

PROPERTY RECORDED:

WATER SUPPLY: • Private • X Public • Well • Spring • Other

EVALUATION METHOD: • X Auger Boring • Pit • Cut

TYPE OF WASTEWATER: • X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	12%	0-5	Br scl ws bk	Fr sss p	—	48"	Few Inf Sap	—	PS 0.3
		5-29	Rc sbk	Fr sss p					
		29-48	Rcl ws bk	Fr sss p					
2	8%	0-3	Br scl ws bk	Fr sss p	—	48"	—	—	PS 0.3
		3-39	Rc sbk	Fr sss p					
		39-48	Rcl ws bk	Fr sss p					
3	3-5%	0-16	Rc sbk	Fr sss p	—	48"	F-c Inf Sap 31"	—	PS 0.35
		16-42	Rcl ws bk	Fr sss p					
		42-48	Rscl ws bk	Fr sss p					
4	3-5%	0-4	R Br scl ws bk	Fr sss p	—	48"	F-c Inf Sap	—	PS 0.35
		4-20	Rc sbk	Fr sss p					
		20-40	Rcl ws bk	Fr sss p					
		40-48	Rscl ws bk	Fr ss sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	1371 ft²	540 ft² +
System Type(s)	Conventional	PP BPS
Site LTAR	0.35	0.3

OTHER FACTORS (.1946):

SITE CLASSIFICATION (.1948): PS

EVALUATED BY: M.A. + Assoc.

OTHER(S) PRESENT:

COMMENTS: