DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____ OF____

PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Dobson B/O OWNER:__ AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: 10/12/95
PROPOSED FACILITY: 3600 gpd
PROPERTY SIZE:_____
LOCATION OF SITE: Lot 58, Kings Landing
WATER SUPPLY: On-Site Well____ Comm. Well___ Public____ Other_____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS 2-4%	0-2	gr lfsl	fr					.37
		2-18	lfsabk rc	fi, sp					
		18-48	mwksbk rcl	fm					
			rare mottles 45"±						
2	LS 2-4%	0-4	gr lfsl	vfr					.35
		4-24	ssbk rc	fi, sp					
		24-48	mwksbk rcl	fm					
3									
4									
5									

AVAILABLE SPACE (.1945)_____ SITE CLASSIFICATION (.1948):_____ SITE LONG-TERM ACCEPTANCE RATE:_____
EVALUATED BY:_____ OTHER(S) PRESENT:_____
COMMENTS:_____