DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Dakin Dev OWNER:__AGENT:__ PHONE:_____
ADDRESS:_____ APPLICATION DATE:_____ DATE EVALUATED: 5/15
PROPOSED FACILITY: 2 BR SFD / Manufactured
PROPERTY SIZE:_____
LOCATION OF SITE: off 24 Emerywood
WATER SUPPLY: On-Site Well____ Comm. Well___ Public___ Other_____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-2	A s c						
		2-18	Sbk c						
		18+	C sbk						
2									
3									
4									
5									

AVAILABLE SPACE (.1945) 4 SITE CLASSIFICATION (.1948): 4 SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: NS OTHER(S) PRESENT:_____
COMMENTS: Soil profile is more than adequate for proposed use. Site is adequate for proposed use. Initial Repair area for future use.