
.ft.
DRIVE
DRIVE
271'
1329
35,697 sq. ft.
1328
44,740 sq. ft.
CONWAY COURT
PUBLIC R/W
40'
55'
129'
299'
230'
DRIVE
780
220
24+00
25+00
23+00
36'
58'
23'
82'
114'
60'
49'
33'
19'
10'
27'
18'
32'
44'
5'
20'
19'
20'
26'
14'
8'
3'
2'
4'
14'

N-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

WNER: _____ APPLICATION DATE _____
DDRESS: _____
ROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ DATE EVALUATED: 3-1-04
OCATION OF SITE: Lot 1329 Ph 13 Thoft PROPERTY SIZE: _____
ATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____ PROPERTY RECORDED: _____
VALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
YPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LAND-SCAPE POSITION/ SLOPE %	HORI-ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-13	wk fsbk sl dk brn sdl	fr ss sp					.3
		13-25	wk-mdfsbk dk brn cl	fr ss sp sty					
		25-43	wk-mdfsbk brn cl	fr ss sp					
		43-54	wk fsbk mottled gry LSCL	fr ss sp					
2	5% ±	0-27	mdfsbk RC	fr ss sp sty					.3
		27-57	wk fsbk yel	fr ss sp	Commercial trap				
3		0-27	mdsbk RC	fr-fi ss p-sp sty					.25 @ ≤ 46"
		27-46	wk fsbk brn	fr ss sp					
		46-53	wk fsbk gry/brn sdl	fr ss sp	few low chr mott ? plowing				
4	#12 TCJ SL CONCRETE								.2

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	15	15
System Type(s)	LPP60RS	LPP60RS
Site LTAR	≤.25	≤.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: DHT
OTHER(S) PRESENT: Paul Ramsey

COMMENTS: _____