IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 200228

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4635-05-9727

APPLICANT: Gary Rinaldi APPLICANT ADDRESS: 36 Barham Dr Smithtown, NY 11787

SITE ADDRESS: 109 Kingsbury Court Mooresville NC 28117 PHONE: 631-724-2880 ALT. PHONE:

SITE DIRECTIONS: Brawley Sch Rd, TL on Chatham Dr, TL on Kingsbury Ct, Lot on corner on L

SUBDIVISION: The Point SECTION: 1B LOT # 14 LOT AREA: 0.8ac DESIGN FLOW: 480gpd L.T.A.R.: 0.3

Septic Tank 1500 (gal) STB Date
Pump Tank 1500 (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 6 Linear Ft: 303
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☑ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI
System Description: LP PPBPS
Repair System Description: LP PPBPS
Maintenance Agreement Required: ☑ YES ☐ NO
☐ GRAVITY ☑ PRESSURE

☑ Residence No. Bedrooms 4
☐ Business No. Persons 8
☐ Other No. Employees
☐ Slab ☑ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☐ Private ☐ Public ☑ Community

Comments / Conditions: *GULLY ON SITE PLAN MUST BE FILLED BEFORE AC IS ISSUED*

Reviewed floor plans 4/1/14, in compliance with original Septic plan.

INITIAL SITE SKETCH

SEE PLAN BY S&ME

(Paul Penninger LSS)

APPROVED BY ICPHD

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration* ☑ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Agent Date: 11-22-13 Installed by:

IMPROVEMENT PERMIT by: Date: 11-19-13 OPERATION PERMIT by: Date:

AUTHORIZATION TO CONSTRUCT by: RS Date: 4/1/14 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK