ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: CRT
ADDRESS: _____
APPLICANT: _____
APPLICATION DATE: _____
DATE EVALUATED: 4-6-11
PROPOSED FACILITY: _____
PROPOSED DESIGN FLOW (.1949): _____
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 14 The Pointe
PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

Now Lot 15

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-11	Weak moderate blocky						PS .25
		11-52	Weak blocky	fr SS, P					
			Fair mapped coating/concretions						
2		0-21	m wk sub blocky	fr SP SO SMW					PS .25
		21-53	wk sub blocky	fr SP SO SMW					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	yes	yes
System Type(s)	III b	LP Panel
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: Re-Approved ICHD 3-11-11 gm
OTHER(S) PRESENT: _____