DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RI Homes OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 5/5/94
PROPOSED FACILITY: 4bedroom SF Dwelling
PROPERTY SIZE:
LOCATION OF SITE: Lot 13, North Shore
WATER SUPPLY: On-Site Well ____ Comm. Well ✓ Public ____ Other ____ EVAL. METHOD: Auger Boring ✓ Pit ____ Cut ____

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ .1956 SAPRLT CLASS	HORIZON LTAR
1	LS 4-6%	0-11	SAB / CL	1:1 / fr			PS		.5
		11-27	SAB / C	1:1 / fi-vfi					.3
		27-48	wk SAB / CL	1:1 / fi					.3
2	LS 4-6%	0-5	SAB / CL	1:1 / fr-fi			~~PS~~		.3
		5-32	SAB / C	1:1 / fi-vfi					
		32-40	wk SAB / CL	1:1 / fi					
			hand sapp @ 40"						
3									
4									
5									

AVAILABLE SPACE (.1945) U* SITE CLASSIFICATION (.1948): U* SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DR Hanson OTHER(S) PRESENT: Paul Swearingen
COMMENTS: Site can be reclassified PS per rule .1956 modified systems PPBPS - Initial system should go on pumped conventional with LTAR repair