IREDELL COUNTY HEALTH DEPARTMENT

15519 IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR M.I. Homes DATE Feb. 18, '93 PERMIT NO. 2623A37

PHONE: Business _____ Home _____

LOCATION 1100 TL 1113 TR Waterford at end on left

S.R. No. _____

SUBDIVISION NAME Pine Isle LOT NO. 37 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 4 No. Bathrooms 3½

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 20,000 ft²+

Soil Characteristics P – clay


Application Rate .3 gal/ft²/day

Topography ~ 2%

Depth to Water Table 3½'+

Rock or other impervious formations None obs

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. _____ Linear Ft. 270'of

Depth of Stone in Lines 16" ABS

Water Supply: Individual ☐ Gravity flow

CW Public ☑

LAKE NORMAN

760

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: Rodger Vernon

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Rodger Vernon, RS

COMMENTS PPBPS Laterals must be installed shallow (28" trench bottom) in order to maintain Approx. 1 foot vertical separation Above 760 Elevation. Plumbing must exit house at ex. ground level in order to accomodate this. Install driveway next to left side boundary to preserve Septic repair area.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold