14250

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR MI Homes DATE 3/20/92 PERMIT NO 26-23-A-41

PHONE: Business 376-9800 Home

LOCATION Isle of Pines Rd, TR into Pine Isle to 6th lot on (L)

S.R. No.

SUBDIVISION NAME Pine Isle LOT NO. 41 SECTION OR BLOCK NO. 1

House ☑ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms 2.5

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 15,000 FT²

Soil Characteristics P - c (ss - sp)


Application Rate .35

Topography 3%

Depth to Water Table > 48"

Rock or other impervious formations None observed

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement ✓ Crawl Space



Size of Tank 1250 / 1250 Gals.

Nitrification Field:

No. of Lines 4 @ 50' x 2'

Sq. Ft. Linear Ft. 200 ±

Depth of Stone in Lines 6" SAND

Water Supply: Individual ☐ COMM

Public ✓ SYSTEM

±16" Prefabricated Panel w/ Pressure Distribution

Installed by

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: Janet Brothers

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY Wesley Spoths R.S.

COMMENTS Trenches 10' from all property lines. Trenches no deeper than 36" to trench bottom. 1 1/4 PVC pipe with @ 3/16" hole drilled per panel (centered in top chamber), 2' pressure head delivered to each lateral end. Pump must deliver 26 gpm at 2 feet pressure head. Alarm bell and float required - 5/32" ANTI SYPHON HOLE ABOVE CHECK VALVE. 160 gallons per dose minimum.

CERTIFICATE OF COMPLETION BY DATE

EXISTING SYSTEM CHECKED BY DATE

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

7/16/92 checked TANKS, OK!!; Checked Drainfield, OK!!; Maintenance agreement rec'd 8/27/92 OK!!