IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Lindsay DATE 6-19-75 PERMIT NO. 131

PHONE: Business 664-2121 Home 664-5967

LOCATION 1100 TL on 1113 TL on 1198 Rt. S. R. No. 1108

SUBDIVISION NAME Sunset Oaks Estates LOT NO. 17 SECTION OR BLOCK NO. 1113


House (4) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (4)
Auto. Dishwasher	Yes (4)	No ( )
Auto. Wash. Machine	Yes (4)	No ( )
Site Suitable	Yes (4)	No ( )

Lot Area 20,000 Sq Ft

Character & Porosity of Soil Sandy Clay Loam
Percolation Rate 23 Mins
Topography 2 to 5 Slope
Depth to Water Table 8' to 10'
Rock or other impervious formations None



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (4)
Public ( )

Installed by Grading Inc

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Ditch had 16" Fall put Two Loads to Correct Fall

CERTIFICATE OF COMPLETION BY Jesse Howerton DATE 6-19-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold