✓ Pin # 4635279989

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Robert Mann DATE 10-7-96 PERMIT NO. 299

PHONE: Business _____ Home _____

LOCATION Hwy 21 to Tyson 2113 Jane TR Ont 1200 left end cul-de-sac (109 Sandy Shore Drive) ✓ S. R. No. _____

SUBDIVISION NAME Surfside Estates ✓ LOT NO. 40 ✓ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre


Character & Porosity of Soil Clay loam Porosity Fair

Percolation Rate 40 Min Fall

Topography Slope

Depth to Water Table 16"+

Rock or other impervious formations None



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by E. T. Service

Plot of System

IMPROVEMENTS PERMIT BY John Houston ✓

COMMENTS: _____

CERTIFICATE OF COMPLETION BY E. C. Woodall DATE 10-9-96

✓

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

pgs. 9 @ 1/2 7/24/26

SCANNED

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold