DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 26-23A-63
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MI Homes OWNER: ✓ AGENT: PHONE:
ADDRESS: 1043 E. Morehead St Charlotte APPLICATION DATE: 6/21/93 DATE EVALUATED: 6/23/93 // Revisit 7/15/93
PROPOSED FACILITY: 4 bedroom SF Dwelling
PROPERTY SIZE: see plat
LOCATION OF SITE: Lot 63, Pine Lake
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-18"	sbk/c	1:1 fi-fr	NONE	NONE	PS	—	.35
		18-48"	wk sbk/sicL	1:1 fr	NONE	NONE	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: D. Johnson OTHER(S) PRESENT:
COMMENTS: Verify limited space - site can be reclassified PS under rule .1956 Modified systems PPBS