DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2G23A64
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: NI Homes OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: 7/27/93 DATE EVALUATED: 7/28/93
PROPOSED FACILITY: 4 bedroom SF Dwelling
PROPERTY SIZE: 20-30,000 ft²
LOCATION OF SITE: Lot 64, Pine Isle
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-6"	gr / scL	1:1 / fr	—	—	PS	—	.5
		6-30	sbk / C	1:1 / vfi	—	—	PS	—	.3
		30-48	sbk / CL	1:1 / fi	—	—	PS	—	.35-.4
2									
3									
4									
5									

AVAILABLE SPACE (.1949): U SITE CLASSIFICATION (.1948): PS per 1956 SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DR Johnson OTHER(S) PRESENT:
COMMENTS: Limited space even for PPBPS