DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2623A62
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MI Homes
ADDRESS: 1943 E. Morehead St. Charlotte, NC
OWNER/AGENT: PHONE:
APPLICATION DATE: DATE EVALUATED: 11/23/93
PROPOSED FACILITY: 4 bedroom SF Dwelling
PROPERTY SIZE: 25,000 ft²+
LOCATION OF SITE: Lot 62, Pine Isle
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ✓ (Basement)

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	[redacted]" LS	0-12"	gr-bk/cl	1:1/efi (dry)	—	—	PS	—	.4
		12-41"	SAB/c	1:1/fi	—	—	PS	—	.3
		41-48"	wk SAB/sicl	1:1/fe-fi	—	—	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): 4 SITE CLASSIFICATION (.1948): 4 SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [redacted] (PS) OTHER(S) PRESENT:
COMMENTS: Site can be reclassified PS per rule .1956 / modified systems PBPS.