DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MT Homes OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 9/29/93
PROPOSED FACILITY: 4 bedroom SF Dwelling
PROPERTY SIZE:
LOCATION OF SITE: Lot 61, Pine Dale
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-23"	gr-SAb / scl	1:1 / fr	—	2 hit loose rock at 23"			
2	SS	0-22"	gr-SAb / scL	1:1 / fr	—	—	PS	—	.5
		22-38"	SAb / C	1:1 / fi-vfi	—	—	PS	—	.3
		38-48	wkSAb / scl	1:1 / fr-fi	—	—	PS	—	.3
3									
4									
5									

AVAILABLE SPACE (.1945): PS SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: DHHmason OTHER(S) PRESENT:
COMMENTS: This site could likely accomodate a conventional field; however the future buyer desires to maximize saving trees so a PPBPS is being utilized.