IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Charles R. Collins DATE 11-16-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 1100 ft. on 1113 1/2 mi on right

S. R. No. _____


SUBDIVISION NAME Surfside Estates LOT NO. 23 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 1/2 acre

Character & Porosity of Soil Clay loam (Porosity Fair)
Percolation Rate Soil borings
Topography 2% Slope
Depth to Water Table ~~4'~~ 3' above lake level
Rock or other impervious formations none



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 500 Linear Ft. 200
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: area where system is repaired is low & soil is not very permeable therefore every effort should be made to have reasonable water use & keep surface water from standing over the

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 11-16-77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold