DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 2623A65
PROPERTY RECORDED: YES
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MI Homes OWNER: ✓ AGENT: PHONE:
ADDRESS: 1063 E. Moorehead APPLICATION DATE: 9/22/93 DATE EVALUATED: Sept. 23, '93
Charlotte PROPOSED FACILITY: 4 bedroom SF dwelling
PROPERTY SIZE: 3/4 AC
LOCATION OF SITE: Pine Lake Sect. 2 Lot 65
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ✓ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	SS	0-15"	cl - sbk	1:1, fi	—	—	PS	—	.3
		15-34"	c - sbk	1:1, vfi	—	—	PS	—	.3
		34-48	wk sbk, sicl	1:1 fr	—	—	PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: [signature] OTHER(S) PRESENT:
COMMENTS: Site can be reclassified PS per rule .1956 modified systems
PPBS