DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET 1 OF 1
PROPERTY I.D.#: 26-23 A 72
PROPERTY RECORDED: Yes
COUNTY: Iredell

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: M I Homes OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED: Feb 1, '94
PROPOSED FACILITY: 4 bedroom SF dwelling
PROPERTY SIZE: ~112' x 240' = .595 Ac.
LOCATION OF SITE: lot 72 Pinnacle - on Lakeshore (Rockwood Rd)
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	25	0-24	SAB / C	1:1 / firm sticky plastic			PS	—	.3
		24-48	wk SAB / SICL	1:1 / sl sticky sl plastic			PS	—	.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945): U SITE CLASSIFICATION (.1948): U SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: OTHER(S) PRESENT:
COMMENTS: Site can be reclassified PS per rule .1956, modified systems PPBPS