DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: ___
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: MI Homes OWNER: AGENT: PHONE: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: Feb 9, '98
PROPOSED FACILITY: 4 bedroom SF dwelling
PROPERTY SIZE: ___
LOCATION OF SITE: lot 73, Pine Isle
WATER SUPPLY: On-Site Well ___ Comm. Well ✓ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	LS	0-18"	SAB / CL	1:1 / sticky slightly plastic		lotsa manganese	PS		.3
		18-48"	SAB / C	1:1 / sticky plastic			PS		.25
2									
3									
4									
5									

AVAILABLE SPACE (.1945) 11 SITE CLASSIFICATION (.1948): 11 SITE LONG-TERM ACCEPTANCE RATE: .25
EVALUATED BY: DHoffman OTHER(S) PRESENT: ___
COMMENTS: Site can be reclassified PS per rule .1956 modified systems
PPBPS