4635 29 7089

15816

# IREDELL COUNTY HEALTH DEPARTMENT

## IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR MI Homes DATE June 16, '93 PERMIT NO. 2623A74

PHONE: Business _____ Home _____

LOCATION 1100 TL 1113 TR Waterford TL Highview Rd. on left past jct w/ Harbor Shore Ct. S.R. No. _____

SUBDIVISION NAME Pine Dale LOT NO. 74 SECTION OR BLOCK NO. _____

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area ~24,000 ft²

Soil Characteristics PSCl/Cly


Application Rate .13

Topography ~4%

Depth to Water Table 74"

Rock or other impervious formations None obs.

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓ Crawl Space




Plot of System (Not to Scale)

Size of Tank 1500/1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. _____ Linear Ft. 270 LF

Depth of Stone in Lines 16" PABPS

Water Supply: Individual ☐ Public ☑ Private Owned

Installed by DeFrasier

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY DRH

COMMENTS Deck not constructed at time septic system installed (5/12/93) Maintenance agreement received 5/26/93 Aeration maintenance verified on 6/16/93 Operation permit

CERTIFICATE OF COMPLETION BY DR Hunter, RS DATE 6/16/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold