IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Colon McArthur DATE 9/10/79 PERMIT NO. 311

PHONE: Business _____ Home _____

LOCATION Rd 1190 / Rt 1113 Enter Isle of Pines ~1/4 mile on R Lot w/ Brick fence S. R. No. _____

SUBDIVISION NAME Isle of Pines LOT NO. 17 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3/4 acre

Character & Porosity of Soil Clay loam
Percolation Rate 80 mpi
Topography 2-4%
Depth to Water Table 4'
Rock or other impervious formations NONE OBSERVED



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 450
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. J. Ervin

IMPROVEMENTS PERMIT BY David R. Hinson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Fred Clemmer/DEH, RWS DATE 9/10/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold