IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR George Barrett DATE 4-19-74 PERMIT NO. 90

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1113 at end Into Isle of Pine S. R. No. 1113

SUBDIVISION NAME Isle of Pine LOT NO. 25 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes (✓)	No ( )
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ½ acre

Character & Porosity of Soil Fine Sandy clay loam Porosity poor
Percolation Rate 35 min/inch
Topography 30% slope
Depth to Water Table 9' to Lake level
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Sam Oswalt

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Bottom of Ditch is 7' above Lake Level.

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-19-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold