ENT

[redacted]ATE OF COMPLETION

[redacted]osorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

[redacted]OR CONTRACTOR Emory W. Atwater DATE 10-12-76 PERMIT NO.

PHONE: Business 873-3476 Home

LOCATION 1400 TL on 1113

S. R. No.

SUBDIVISION NAME Isle of Pine LOT NO. SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ½ acre


Character & Porosity of Soil Sandy loam (Porosity Fair)

Percolation Rate not taken

Topography 7 290 Slope

Depth to Water Table [redacted] Stob to lake level

Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

750 Sq. Ft. [redacted] Linear Ft. 300

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-12-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold