IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

46

OWNER OR CONTRACTOR Jec A. Gable DATE 3-18-74 PERMIT NO.

PHONE: Business Home

LOCATION 1100 ~~Rt~~ TL on 1113 on right before entrance into Isle of Pine S. R. No. 1113

SUBDIVISION NAME Map 26-2 LOT NO. 3 SECTION OR BLOCK NO.


House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 20,000 sq feet

Character & Porosity of Soil Clay loam (Acceptable good)
Percolation Rate 22 min/1 inch
Topography 3% slope
Depth to Water Table lot
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 635 Linear Ft. 255
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Orbison

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 3-18-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold