4635 37 4202

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donna Donatelli DATE 10/31/79 PERMIT NO. 379

PHONE: Business _____ Home _____

LOCATION 1100 TL on 1113 3rd House on Rt after entering Isle of Pines S. R. No. _____

SUBDIVISION NAME Isle of Pines LOT NO. 5 SECTION OR BLOCK NO. _____


SURFSIDE ESTATES

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )	Character & Porosity of Soil Clay loam
Auto. Dishwasher	Yes	(✓)	No	( )	Percolation Rate 50 min
Auto. Wash. Machine	Yes	(✓)	No	( )	Topography 2-4%
Site Suitable	Yes	(✓)	No	( )	Depth to Water Table 4'+
					Rock or other impervious formations none obs.

Lot Area ~1/2 AC



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 462 Linear Ft. 154
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Wayne Robinson

The proposed / existing GARAGE addition does not appear to impact the existing septic system.
**NOTE: _____

_____ REHS R.S.
Date: 12-3-09
ICHD-Environmental Health Division

IMPROVEMENTS PERMIT BY _____

COMMENTS: Repair starts 3' wide and tapers into 6' wide

CERTIFICATE OF COMPLETION BY Harold R. Johnson DATE 10/31/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold