DEPARTMENT OF ENVIRONMENT AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ *of* ____
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Ryan West APPLICATION DATE _____
ADDRESS: _____ DATE EVALUATED: 10/6/21
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE: _____
LOCATION OF SITE: Lot 27 Sunset Estates PROPERTY RECORDED: _____
WATER SUPPLY: ☑ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☑ Sewage ☐ Industrial Process ☐ Mixed

Crawl Space

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 6-8% Rolling	0-14	sbk / cl	FR SS-SP	PS / BR				
		15-30	MK sbk / cl	FR SS-SP	PS / R				
		31-48	MW sbk / l	VFR-SS-SP	PS / 4R				.3
2	Level FP	0-12	sbk cl	FR SS-SP	PS BR				
		13-31	MW sbk / cl	FR SS-SP	PS R				
		32-48	MF sbk / cl	VFR SS-NP	PS / 4R	PS			.3
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	< 83'
System Type(s)	PPBPS	
Site LTAR	.3	

OTHER FACTORS (.1946): < 83 Recording
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

COMMENTS: _____