Bob Weaver

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR [redacted] Linn DATE 11-2-96 PERMIT NO. 171

PHONE: Business _____ Home _____

LOCATION Hwy 71 S on NC3 at end S. R. No. _____

SUBDIVISION NAME Isle of Pine LOT NO. 9 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Large

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Mod. to Faster
Topography 2-20% Slope
Depth to Water Table 6' to Lake level
Rock or other impervious formations None

Lake



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by E.J. Crum

Dig 1' X 100' 3 lines

IMPROVEMENTS PERMIT BY John Hewton

COMMENTS: Bottom of Ditch is 2' 3" above the High water mark of Lake

CERTIFICATE OF COMPLETION BY [signature] DATE 11-7-96

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold