IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Luther Eutner Builders DATE 7-9-76 PERMIT NO. 180

PHONE: Business _____ Home _____

LOCATION 1100 TL on 113 at end S. R. No. 113

SUBDIVISION NAME Isle of Pine LOT NO. 8 SECTION OR BLOCK NO. II


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ½ acre

Character & Porosity of Soil Clay loam Porosity Fair
Percolation Rate Soil borings
Topography 2 sq. slopes
Depth to Water Table 6' + to lake level
Rock or other impervious formations none



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

Ditch
9'X100'
3 lines

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Bottom of Ditch is 2'9" above high water mark of lake

CERTIFICATE OF COMPLETION BY _____ DATE 10-7-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold