4635-44-6072

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Raymond Avery DATE 7-15-04 PERMIT NO. 44

PHONE: Business _____ Home _____

LOCATION 1100 Turn on 115 at end on right

S. R. No. 115

SUBDIVISION NAME Isle of Pine LOT NO. 13 SECTION OR BLOCK NO. 2


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 1 acre

Character & Porosity of Soil Fine sandy loam / Porosity good
Percolation Rate 2 Minutes
Topography Rolling
Depth to Water Table 60"
Rock or other impervious formations none



Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 320
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by E.T. Irvin

IMPROVEMENTS PERMIT BY T. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY T. C. Moore DATE 7-15-04

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold