4635-44-6396 [redacted]

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed Griffin Co DATE 11-22-74 PERMIT NO. 320

PHONE: Business 537-4254 Home

LOCATION Rd 1100 Tl on 1113 Follow to end

S. R. No.

SUBDIVISION NAME Isle of Pine LOT NO. 24 SECTION OR BLOCK NO. II

Site Address: 703 Isle of Pines Rd. Mrsvl

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area approx 30,000 sq ft


Character & Porosity of Soil Fine Sandy Clay Loam (brown)

Percolation Rate 30 min / in

Topography 2 2% Slope

Depth to Water Table 8 to 10' to Lake Level

Rock or other impervious formations None



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 990 Linear Ft. 330
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by F. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY John Houston DATE 1-22-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold