4635-44-6396

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Ed Smith Co DATE 11-2-22 PERMIT NO. 820

PHONE: Business 522-4352 Home

LOCATION 601 Mac Tx to 115 Bo Hwy to end

S. R. No.


SUBDIVISION NAME Isle of Pine LOT NO. 24 SECTION OR BLOCK NO. II

House ( ) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Fine Sandy Clay Loam Moderate
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	30 min 1"
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Level Site
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6 to 10' state Level
			Rock or other impervious formations	None

Lot Area 1/2 + acre per code



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 270 Linear Ft. 330
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by E.T. Sain

IMPROVEMENTS PERMIT BY L.C. Moore

COMMENTS:

CERTIFICATE OF COMPLETION BY John Christian DATE 11-23-22

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold