IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

Ground Absorption Sewage Disposal System - G. S. Chapter 130 Article 13C)

OWNER OR CONTRACTOR R. W. Lail DATE 4-22-76 PERMIT NO.

PHONE - Business Home 872-2323

LOCATION Hwy 21 S. of Troutman

S.I. No.

SUBDIVISION NAME Lake of Pines LOT NO. 20 SECTION OR BLOCK NO. 2

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2 Character of Soil Clay Loam

Garbage Disposal Unit Yes ( ) No (✓) Percolation Rate 30 min/inch

Auto. Dishwasher Yes ( ) No (✓) Topography Level

Auto. Wash Machine Yes (✓) No ( ) Depth to Water Table 24"+

Site Suitable Yes (✓) No ( ) Rock or other impervious formations None

Lot Area 1 Acre

Size of Tank 1500 Gal.

Nitrification Field

No. of Lines 3

Size 100' Lines or Trench

Depth of Stone in Lines 24"

Water Supply - Individual (✓)

Public ( )

Installed by R. W. Lail

Sketch of System

IMPROVEMENTS PERMIT BY

COMMENTS

CERTIFICATE OF COMPLETION BY DATE 4-22-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy - White Inspection Dept. Copy - Yellow Sanitarian's Copy - Pink Owner's Copy - Gold