IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Dewane Lewis DATE 12-2-76 PERMIT NO. 1

PHONE: Business _____ Home _____

LOCATION 100 T L on 113 at end

S. R. No. _____

SUBDIVISION NAME Isle of Pine LOT NO. 12 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area ½ acre

Character & Porosity of Soil Clay Loam . Porosity Fair
Percolation Rate 25 min / inch
Topography 2 to 4 % Slopes
Depth to Water Table 7' on Front Side
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 425 Linear Ft. 850
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by E. J. Ervin

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Hawkins DATE 1-2-76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold