13366

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Leonard Crenen DATE 9/9/91 PERMIT NO. 26-8-A-22

PHONE: Business _____ Home N/A

LOCATION Marina Village - Southwood Drive, TR off Stutts Rd, TL to 3rd lot on (R)

S. R. No. _____

SUBDIVISION NAME Marina Village LOT NO. 22 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 20,000 FT²

Character & Porosity of Soil P - clay (sf)
Percolation Rate .35
Topography 2-5%
Depth to Water Table > 48"
Rock or other impervious formations None found

Basement with Plumbing _____ Basement without Plumbing _____ No Basement ✓



Plot of System

1000 Septic Tank
Size of Tank 1000 Pump Tank Gals.

Nitrification Field:
No. of Lines 3@ 60' X 24"
Sq. Ft. _____ Linear Ft. 180
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: mailed to John Cook Apple Homes as requested.

IMPROVEMENTS PERMIT BY Wesley Sparks R.S.

COMMENTS: Trenches no deeper than 28" to trench bottom. 41 panels 3/16" hole (2 per panel) in PVC pipe. No more than 2' of pressure head on any trench. High water alarm and float required in pump tank on seperate circuit from pump. Bell, buzzer or light required in house.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold