0847

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR ROBERT C. MONSON DATE 8/16/88 PERMIT NO. 21C

PHONE: Business _____ Home _____

LOCATION 1100 TL Stutts TR Southwood Pk TL Southwood Pk. 3rd on R. S. R. No. _____

SUBDIVISION NAME MARINA VILLAGE LOT NO. 19 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other REPAIR ADDITION (NO BR.)


No. Bedrooms 3 No. Bathrooms 2 1/2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	existing
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	
			Rock or other impervious formations	

R/3

Lot Area 20000 ft+2+

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank: Pump 1500 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. _____ Linear Ft. 75' of 16"

Depth of Stone in Lines T&J panels

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: James Cook

IMPROVEMENTS PERMIT BY Andre C. Prince

COMMENTS: Install pump tank after a flow divider and pump to field near road. Install shallow drainfield and keep ON CONTOUR. High water Alarm and floats must be mounted and finaled before completion.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold