IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Luther Butner Builders DATE 4-13-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S TR on 1102 at end TR 1/4 mi on left

S. R. No. _____

SUBDIVISION NAME Sailors Lair LOT NO. 25 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area 3/4 acre

Character & Porosity of Soil clay loam Porosity Fair
Percolation Rate 5 of 3 Borings
Topography 3% slope
Depth to Water Table 6 to 8"
Rock or other impervious formations None



Plot of System

1500 Gal Tank
Size of Tank 500 Gal Pump T. Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lee Lackey

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-13-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold