IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Luther Rutherford DATE 4-12-95 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 115 S TR on 1132 at end TR. turn on left _____ S. R. No. _____

SUBDIVISION NAME Sailing Lair LOT NO. 25 SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes	( )	No	(✓)	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 3 Acres

Character & Porosity of Soil Clay loam brn/yel
Percolation Rate 5 Showed 3
Topography Side Slope
Depth to Water Table 6 in
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gal Tank on Tee Pipes Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 200 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Lee Lackey

IMPROVEMENTS PERMIT BY John Hewitson

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 4-18-95

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold