IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Wayne Ellis DATE 9-12-78 PERMIT NO. 221

PHONE: Business _____ Home _____

LOCATION 1155 TR on 1102

S. R. No. _____


SUBDIVISION NAME Sailors Lair LOT NO. 23 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	60 min/5cm	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 % slope	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6' to 8'	
			Rock or other impervious formations	None	

Lot Area ¾ acre



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Lee Lankey

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY John Houston DATE 9-12-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold