IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Courtney DATE July 31, '78 PERMIT NO. 184

PHONE: Business _____ Home _____

LOCATION 1102 at end T.L. at end of rd.

S. R. No. _____

SUBDIVISION NAME Taylors Fair LOT NO. 22 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	(✓)	No	( )
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 1 Ac.


Character & Porosity of Soil Clay Loam

Percolation Rate —

Topography 2-4%

Depth to Water Table _____

Rock or other impervious formations _____



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 675 Linear Ft. 225
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Bill Bowman

IMPROVEMENTS PERMIT BY J. C. Morris

COMMENTS: Nitrification line has ± 10" cover at end. Bottom of tank estimated to be ± 2" above 760 elevation.

CERTIFICATE OF COMPLETION BY [signature] DATE July 31, '78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold