IREDELL COUNTY HEALTH DEPARTMENT 4635506285

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Butner Builders DATE July 13, '79 PERMIT NO. 242

PHONE: Business _____ Home _____

LOCATION 1153 TR on 1102

S. R. No. _____


SUBDIVISION NAME Saibers Lair LOT NO. 21 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay loam	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80 mpi	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	6'+	
Lot Area ½ AC			Rock or other impervious formations	none obs.	

LAKE



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 1125 Linear Ft. 375
Depth of Stone in Lines 24"
Water Supply: Individual (✓)
Public ( )

Installed by E J Ervin

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Layout changed w/out notifying Health Dept. System put in only way possible.

CERTIFICATE OF COMPLETION BY David K. Henson DATE 7-13-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold